



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **75244-011-03**

Valid from: 2016 02 14
until: 2018 02 14

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **LAUMAYER S.A.**
Cra 50C No. 10Sur - 61
Medellin
Colombia

Product: **Connector for industrial purposes**

Basis for this given right is the conformity of the products with the requirements of the technical standards listed in this certificate as stated in the file(s) Ref.-No(s). **TGM-VA EE 35317**.

This certificate establishes the conformity of the tested specimen and of all products manufactured strictly identical to the submitted one.

Österreichischer Verband für Elektrotechnik
Head of Testing & Certification

Digitally signed by W. Martin
Email=w.martin@ove.at

Vienna, 2016 01 19

Dipl.-Ing. W. Martin



OVE - Testing & Certification

Accredited by the Federal Ministry of Science, Research and Economy as Certification Body for products within the scope as given in the official decree and published under www.en.bmwf.at/accreditation





Manufacturer:

ID >43<

Factory location(s):

ID >43<

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01

ÖVE/ÖNORM EN 60309-2:2013-03-01

This certificate is the basis for the EC Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity with the listed standards as defined by the **EC Low-Voltage Directive 2006/95/EC**.

Product: Connector for industrial purposes

Type designation:

Rating:

Trademark:

TAR16/213

Rated current: 16 A
IP44 or IP44/IP54
2P+E

VCP Electric

TAR16/214

Rated current: 16 A
IP44 or IP44/IP54
3P+E

VCP Electric

TAR16/215

Rated current: 16 A
IP44 or IP44/IP54
3P+N+E

VCP Electric

TAR16/2132

Rated current: 16 A
IP67 or IP66/IP67
2P+E

VCP Electric

TAR16/2142

Rated current: 16 A
IP67 or IP66/IP67
3P+E

VCP Electric

TAR16/2152

Rated current: 16 A
IP67 or IP66/IP67
3P+N+E

VCP Electric

OVE - Testing & Certification

Accredited by the Federal Ministry of Science, Research and Economy as Certification Body for products within the scope as given in the official decree and published under www.en.bmwf.gv.at/accreditation



Typelist

Type	Rated current [A]	Earthing contact position h	Rated operating voltage [V]	Frequency [Hz]	Insulation voltage V
TAR16/213 TAR16/2132	16	1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	>50 - 250	DC	690
		4	100 - 130	50 and 60	690
		6	200 - 250	50 and 60	690
		7	480 - 500	50 and 60	690
		9	380 - 415	50 and 60	690
		10	>50	>100 - 300	690
TAR16/214 TAR16/2142	16	12	Supply from an isolating transformer	50 and 60	690
		1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	380 440	50 60	690
		4	100 - 130	50 and 60	690
		5	600 - 690	50 and 60	690
		6	380 - 415	50 and 60	690
		7	480 - 500	50 and 60	690
		9	200 - 250	50 and 60	690
		10	>50	>100 - 300	690
		11	440 - 460	60	690
		12	Supply from an isolating transformer	50 and 60	690
TAR16/215 TAR16/2152	16	1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	220/380 250/440	50 60	690
		4	57/100 - 75/130	50 and 60	690
		5	347/600 - 400/690	50 and 60	690
		6	200/346 - 240/415	50 and 60	690
		7	277/480 - 288/500	50 and 60	690
		9	120/208 - 144/250	50 and 60	690
		10	>50	>100 - 300	690
		11	250/440 - 265/460	60	690
		12	Supply from an isolating transformer	50 and 60	690

OVE - Testing & Certification

Accredited by the Federal Ministry of Science, Research and Economy as Certification Body for products within the scope as given in the official decree and published under www.en.bmwf.gv.at/accreditation